

# CERTIFICATE

Issued to:  
Applicant:  
**CE+T Technics S.A.**  
Rue Hauzeur 17  
4031 Angleur  
Belgium

Manufacturer/Licensee:  
**CE+T Technics S.A.**  
Rue Hauzeur 17  
4031 Angleur  
Belgium

Product : Emergency lighting with LEDs  
Trade name : CE+T  
Types : LUCIOLE 15NPA ANTI-PANIC  
LUCIOLE 15NPA ESCAPE-ROUTE  
LUCIOLE 15NPLA ANTI-PANIC  
LUCIOLE 15NPLA ESCAPE ROUTE

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60598-1:2008, EN 60598-2-22:1998;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2155579

DEKRA hereby grants the right to use the ENEC KEMA-KEUR certification mark.

The ENEC KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the ENEC KEMA-KEUR certification agreement and under the conditions of the ENEC KEMA-KEUR certification agreement.

This certificate is issued on: 26 October 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2164084.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood  
Managing Director



A.P. van der Veen  
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE  
DUTCH ACCREDITATION  
COUNCIL



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	:	Emergency lighting with LEDs
trade name	:	CE+T
types	:	LUCIOLE 15NPA ANTI-PANIC LUCIOLE 15NPA ESCAPE-ROUTE LUCIOLE 15NPLA ANTI-PANIC LUCIOLE 15NPLA ESCAPE ROUTE
rated voltage	:	230 V
nature of supply	:	ac
frequency	:	50 Hz
class	:	II
degree of protection	:	see product data per type
max. ambient temperature (ta)	:	0...+45 °C

**Additional information**

There are two types of optic lenses that can be use in each LUCIOLE model:

- ER: Escape-Route
- AP: Anti-panic

**Product data - type LUCIOLE 15NPA ANTI-PANIC**

degree of protection : IP40

**Product data - type LUCIOLE 15NPA ESCAPE-ROUTE**

degree of protection : IP40

**Product data - type LUCIOLE 15NPLA ANTI-PANIC**

degree of protection : IP20

**Product data - type LUCIOLE 15NPLA ESCAPE ROUTE**

degree of protection : IP20

**TESTS****Test requirements**

EN 60598-1:2008 + A11:2009

EN 60598-2-22:1998 + A1:2003 + A2:2008

**Test result**

The test results are laid down in DEKRA test file 2164084.00.

**Conclusion**

The examination proved that all test requirements were met.

Tested by : H.J. Rikkers

A handwritten signature in black ink, appearing to be 'H.J. Rikkers', written over a horizontal line.

Checked by : T.H.J.M. Michels

A handwritten signature in black ink, appearing to be 'T.H.J.M. Michels', written over a horizontal line.

**Factory location**  
CE+T Technics S.A.  
Rue Hauzeur 17  
4031 Angleur  
Belgium